



San Simon School

Bureau of Indian Education

HC 01 Box 8292
Sells, Arizona 85634
Telephone (520) 362-2231 Fax (520) 362-2405
Principal- Frank Rogers

Date: January 31, 2022

Re: **Notification of Asbestos to Parents, Students and Staff**

Dear Building Occupants,

The EPA's Asbestos Hazard Emergency Response Act (AHERA) requires inspection of all school buildings, public or private, kindergarten through 12th grade. An inspection at **the San Simon School located at Highway 86 Mile Marker 75, Sells, Arizona** was conducted. Samples of the AHERA and NESHAP suspect building materials were collected from the school. The analysis results indicate that asbestos was detected in the sampled building materials in the following buildings.

- **#611 Multi Purpose**
 - **Stage, Break Room, Clinic, Custodial Room, Storage Rooms—12" White w/Specks Floor Tile/Mastic**
- **#612 Kindergarten**
 - **Classrooms, Hallways, Storage Rooms- 12" Tan/Brown Floor Tile/Mastic**
- **#613 Classrooms**
 - **Classrooms, Hallways—12" Tan/Brown Floor Tile/Mastic**
 - **Exterior—Roofing**

All fire doors located throughout the buildings are assumed to be ACBM.

All building materials are in good condition and will be managed in place.

Do not disturb these materials. These materials will remain in place, unless they become damaged. In the event that they do become damaged, removal is the first option.

Custodial and maintenance workers will need the AHERA two hour awareness training. Properly trained maintenance and custodial personnel will follow certain cleaning procedures to ensure that no fibers are released. In addition, all renovation must be approved to ensure that proper procedures are followed to protect the health and safety of the occupants and workers.

If you have any questions, please contact Lee Ivey at 520-362-2231

Sincerely

Frank Rogers/ Principal